



**Addendum 2**

NJSDA  
1 West State Street  
Trenton, NJ 08625  
Phone: 609-777-1922  
Fax: 609-656-4609

**Date: August 19, 2010**

**PROJECT #: EP-0012-C01**

**DESCRIPTION: Horton Elementary School Roof Repairs**

This addendum shall be considered part of the Bid Documents issued in connection with the referenced project. Should information conflict with the Bid Documents, this Addendum shall supercede the relevant information in the Bid Documents.

- 
- 1) The bid date has been changed to September 1, 2010
  - 2) Drawing A5.1 please make the following changes to the Keyed Notations.

Keyed Notation 4: Delete text reading, "Remove masonry material back to sound material and reconstruct with new brick to match existing. See Detail 12/A7.1."

ADD the following text, "Remove masonry back to sound material up to full thickness of wall and reconstruct with new materials to match existing. Similar to Detail 12/A7.1. As required to perform this work remove and replace interior finishes at opposite side of wall at this area. Contractor is responsible for temporary support of masonry above area of work."

Keyed Notation 6:

Delete Keyed Notation 6 in its entirety.

**End of Addendum No. 2**

David Crockett  
NJSDA

8-19-2010

Date

**Addendum 2**

NJSDA  
1 West State Street  
Trenton, NJ 08625  
Phone: 609-777-1922  
Fax: 609-656-4609

**Date: August 19, 2010**

**PROJECT #: EP-0012-C01**

**DESCRIPTION: Horton Elementary School Roof Repairs**

Addendum No. 2

**Acknowledgement of Receipt of Addendum**

Contractor must acknowledge the receipt of the Addendum by signing in the space provided below and returning via fax to 609-656-4609. Signed acknowledgement must be received prior to the Bid Due Date. Acknowledgement of the Addendum must be made in Section E.6 of the Price Proposal Submission.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Print Name

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Date