



<Addendum 1>

NJSDA
1 West State Street
Trenton, NJ 08625
Phone: 609-984-4781
Fax: 609-656-4633

Date: March 22, 2011

PROJECT #: EP-0050-C01-RB1

DESCRIPTION:

This addendum shall be considered part of the Bid Documents issued in connection with the referenced project. Should information conflict with the Bid Documents, this Addendum shall supercede the relevant information in the Bid Documents.

1. This contract is hereby designated as EP-0050-C01-RB1
2. List of drawings – Page ASB1 states Building will be occupied during asbestos abatement. Correction: Building is to be vacant during Asbestos Containing Material (ACM) abatement.
3. List of drawings –

Sheet H2.2 – Removed the ‘B’ vent installation detail. ‘B’ venting is not to be used on the steam boiler system. Also, the gas service for the steam boilers has been more defined to indicate the required gas pressure requirements for the boilers.

Sheet H2.3 the gas service for the hot water boilers has been clarified to indicate coordination with the gas company has begun.

Sheet H3.2 the steam boilers schedule has been revised to indicate the boilers shall be ordered with a gas train capable of operating a minimum of 1PSI of natural gas pressure and that utility required gas lockouts will be required.

End of Addendum No. 1

<i>Katherine M. DeBello</i>	<i>03/30/11</i>
_____ NJSDA	_____ Date
PM Name	

<Addendum 1>

NJSDA
1 West State Street
Trenton, NJ 08625
Phone: 201-288-2600
Fax: 201-288-2662

Date: March 14, 2011

PROJECT #: EP-0050-C01-RB1

DESCRIPTION:

1. This contract is hereby designated as EP-0050-C01-RB1
2. List of drawings- Page ASB1 states Building will be occupied during asbestos abatement. Correction: Building is to be vacant during Asbestos Containing Material (ACM) abatement.
3. List of drawings – Sheets H2.2, H2.3 and H3.2 have been revised.

Addendum No. 1

Acknowledgement of Receipt of Addendum

Contractor must acknowledge the receipt of the Addendum by signing in the space provided below and returning via fax to (609-656-4609). Signed acknowledgement must be received prior to the Bid Due Date. Acknowledgement of the Addendum must be made in Section E.6 of the Price Proposal Submission.

Signature

Print Name

Company Name

Date