32 E FRONT STREET P.O. BOX 991 TRENTON, NJ 08625-0991 609-943-5955

Addendum No. 1

NJSDA 32 E. Front Street

Trenton, NJ 08625 Phone: 609.858.2986

Fax: 609.656.7238

DATE:

April 8, 2015

PROJECT #:

EP-0085-C01

DESCRIPTION:

Vineland HS South, Emergent - HVAC System Replacement

This addendum shall be considered part of the Bid Documents issued in connection with the referenced project. Should information conflict with the Bid Documents, this Addendum shall supercede the relevant information in the Bid Documents.

A. CHANGES TO THE PROCUREMENT PROCESS:

1. Not applicable.

B. CHANGES TO THE PROJECT MANUAL:

1. Not applicable.

C. CHANGES TO THE DRAWINGS:

1. Not applicable.

D. BIDDER'S QUESTIONS, REQUESTS FOR INFORMATION AND RESPONSES:

1. **Question:** Is it acceptable to utilize Pro-Press Systems for hydronic piping 4" and smaller to reduce risk of fire and fumes during occupied hours?

Answer: Piping applications shall match Specification Section 232113 ("Hydronic Piping"), subsection 3.1 ("Piping Applications").

2. Question: Confirm abatement contractor is responsible for boiler demo.

Answer: The abatement contractor is responsible for removal of the asbestos from the boiler and its associated components. The remaining work associated with demolition of the boiler may be self- performed by the General Contractor, or at the option of the General Contractor, the remaining demolition work may be performed by the abatement contractor or another subcontractor, as it is within the General Contractor's discretion as to how to define the means and methods to best accomplish the Project work.

Addendum #: 1

Project #: EP-0085-C01

2. **Question:** In reviewing the specs for the project I noticed Tozour Energy was listed as the only acceptable vendor. We ran into a similar issue on the Bridgeton High project where a sole sourced vendor was listed. This was ultimately revised to accept others vendors based on the proprietary vendor state statute. Do you know if this project has attained a waiver from the State approving Tozour as a sole source provider of services for the ATC systems?

Answer: Yes, the district has secured a waiver from the State approving Tozour as a sole source provider.

E. CHANGES TO PREVIOUS ADDENDA:

1. Not applicable.

F. ATTACHMENTS:

1. Not applicable.

G. SUPPLEMENTAL INFORMATION:

1. Not applicable.

Any bidder attempting to contact government officials (elected or appointed), including NJSDA Board members and NJSDA Staff in an effort to influence the selection process may be immediately disqualified.

End of Addendum No. 1

Prøgram Officer

Addendum #: 1

Project #: EP-0085-C01

Addendum #1

NJSDA 32 East Front Street Trenton, NJ 08625 Phone: 609.858.2986 Fax: 609.656.7238 DATE: April 8, 2015 PROJECT #: EP-0085-C01 **DESCRIPTION:** Vineland HS South, Emergent - HVAC System Replacement Acknowledgement of Receipt of Addendum Contractor must acknowledge the receipt of the Addendum by signing in the space provided below and returning via fax to (609-656-7238). Signed acknowledgement must be received prior to the Bid Due Date. Acknowledgement of the Addendum must be made in Section E.6 of the Price Proposal Submission. Signature Print Name

Date

Addendum #: 1

Company Name

Project #: EP-0085-C01