



Addendum No. 1

NJSDA
32 E Front Street
Trenton, NJ 08625
Phone: 609-858-2981

DATE: December 23, 2021

PROJECT #: EP-0108-C01

DESCRIPTION: Plainfield High School Boiler Room Repairs

This Addendum shall be considered part of the Bid Documents issued in connection with the above-referenced project . Should information in this addendum conflict with the Bid Documents, this Addendum shall supersede the relevant information in the Bid Documents.

A. CHANGES TO THE PROCUREMENT PROCESS:

1. Modifications to Advertisement, Request for Proposals, and Related Documents

a. Not Applicable

B. CHANGES TO THE PROJECT SUMMARY:

NOTE: Additions are shown in **bold and underline** text; deletions are shown in ~~*strikethrough and italics*~~.

1. Not applicable.

C. BIDDER'S QUESTIONS, REQUESTS FOR INFORMATION AND RESPONSES:

1. Question: Will the project be inspected locally or by the DCA?

Response: All inspections are to be conducted by the New Jersey Department of Community Affairs (NJDCA).

2. Question: Has the respective authority done a courtesy review of the plans yet?

Response: All plans have been reviewed and released by the NJDCA.

3. Question: Is the existing Boiler Room Roof covered by a Warranty? If so, please provide the contact info for the Roofing Contractor.

Response: The existing boiler room roof is not covered by a warranty.

4. Question: Is a dedicated QA/QC Person and a Site Safety Person required to be on site? Can the Site Superintendent cover both rolls on site?

Response: A separate dedicated QA/QC and Site Safety Person is required for this project.

5. Question: Please confirm that we do not need to name an HVAC, Electrical, Plumbing or Structural Steel subcontractor on the Price Proposal.

Response: Confirmed. The scope of work identified in the Contract Documents does not require the engagement of an HVAC, Electrical, Plumbing or Structural Steel subcontractor, and SDA will not reject a proposal solely for failure to identify an HVAC, Electrical, Plumbing or Structural Steel subcontractor.

D. CHANGES TO PREVIOUS ADDENDA:

a. Not applicable.

E. ATTACHMENTS

1. Not Applicable

F. SUPPLEMENTAL INFORMATION

1. Not Applicable

Any bidder attempting to contact government officials (elected or appointed), including NJSDA Board members, NJSDA Staff (except for Procurement), Technical Review Committee members, NJSDA Consultants, and School District officials for information relating to this project or in an effort to influence the selection process may be immediately disqualified.

End of Addendum No. 1



Addendum No. 1

NJSDA
32 E. Front Street
Trenton, NJ 08625
Phone: 609-858-2981

DATE: December 23, 2021

PROJECT #: EP-0108-C01

DESCRIPTION: Plainfield High School Boiler Room Repairs
Plainfield, NJ
Addendum No. 1

Acknowledgement of Receipt of Addendum

Contractor must acknowledge the receipt of the Addendum by signing in the space provided below and returning via email to Alison Perry at APerry@njsda.gov. Signed acknowledgement must be received prior to the Bid Due Date. Acknowledgement of the Addendum must be made in **Section F.5** of the Price Proposal Submission for Emergent Projects.

Signature

Print Name

Company Name

Date