



NJ SCHOOLS DEVELOPMENT AUTHORITY



Addendum No. 5

DATE: September 8, 2009
PROJECT #: Marshall Street Elementary School
Paterson, NJ
SDA Contract #PA-0006-C03

The Bid Due Date remains unchanged at September 22, 2009 at 2:00 PM.

The following revisions to the Bid Documents by Addendum #5 are:

A. CHANGES TO THE SPECIFICATIONS:

1. Regarding Specification Section 04221 CONCRETE MASONRY UNITS issued in Addendum #3:

CHANGE PART 1.1.A to "Section includes: Concrete masonry units with factory applied coating." **OMIT** "reflective/ground texture and split face".

CHANGE PART 1.2.A.7 to "ASTM C744-05 – Prefaced Concrete and Calcium Silicate Masonry Units."

CHANGE PART 1.4.B.1 to "Coated CMU by Dillon as specified in this Section and material sizes reflected in the architects design."
OMIT "Split Face".

ADD to PART 2.1 the following acceptable manufacturers: Trenwyth Plus and Beavertown Block.

ADD to PART 2.1.C the phrase "Or approved equal".

DELETE PART 2.2.C Sealer, in it's entirety.

CHANGE PART 2.3.E. to "Reflective Face: Conform to ASTM C-744-05 when tested for:" **ADD** "5. Soiling and Cleansability".

DELETE PART 2.3.G.1.b "Splitface Finish".

B. CLARIFICATIONS

1.

Q: Reference is made to Appendix E, "Geothermal Test Boring Report" issued with Addendum #2. In it, your consultant recommends that the bores do not exceed 425 feet, but the contract drawings show 500 feet. Will 425 feet be acceptable?

A: The geothermal driller recommends that the bores do not exceed 425 feet depth. After reviewing the latest bore report during the construction document phase, we revised our original bore depth from 590 to 500 feet as per the construction drawings/bid documents. The 425 feet bore depth is NOT acceptable considering the allowable borefield cannot be expanded.

2.

Q: As per drawings A0.3 – A0.5, it indicates to spray fireproof, 1 hour rating, on staircases. Are these the only areas to be sprayed? Please clarify.

A: Spray-on fireproofing is required in all areas hatched per the designated symbol shown on Drawing A0.3 under "Fire Separation Assemblies".

3.

Q:

- (1) Spec. 08410-2.3.C calls for stainless steel cladding. Where is this used?
- (2) Spec. 08410-3.2.1 refers to installing cladding with hairline joints...completely cover surfaces of framing so no aluminum is visible in finished construction. Why does the specification then call for the aluminum to be finished in a 3 coat 70% kynar?
- (3) Spec. 08911-2.1.B.1 also refers to aluminum cladding. Please clarify.
- (4) Spec. 08911-2.1.A.4 calls for Vistawall Architectural products, series 2600. Their curtain wall system is the CW-250. Is the 2600 a typo?

- A:**
- (1) No cladding required at storefronts
 - (2) No cladding required at storefronts. 3-coat kynar finish required at all aluminum windows, storefront and curtain wall framing.
 - (3) See CW-1, North Entry for cladding (Insulated Panels).
 - (4) Reference to 2600 is a typo. Should read CW-250.

4.

Q: Drawing C3 shows rails outside of Music Classroom, Stair #3, and 4th Grade Classrooms. However, drawings A-0.6, A1.2, and A1.5 do not show these rails. Please clarify if they are required.

A: Provide handrails as shown on civil drawings.

5.

Q: Please clarify extent of guardrail shown on 6/A-0.6.

A: Extent of guardrail is shown on plaza plan at ramp (drawing 1/A-0.6)

This addendum shall be considered part of the Bid Documents issued in connection with the referenced project. Should information conflict with the Bid Documents, this Addendum shall supersede the relevant information in the Bid Documents.

End of Addendum No. 5


NJ Schools Development Authority 9/8/09
Jack Coco, Project Manager



NJ SCHOOLS DEVELOPMENT AUTHORITY



Bovis
Lend Lease

Addendum No. 5

DATE: September 8, 2009

PROJECT #: Marshall Street Elementary School
Paterson, NJ
Contract #PA-0006-C03

Acknowledgement of Receipt of Addendum

Contractor must acknowledge the receipt of the Addendum by signing in the space provided below and returning via fax to 609-951-0038. Signed acknowledgement must be received prior to the Bid Due Date. Acknowledgement of the Addendum must be made in Section E.6 of the Price Proposal Submission.

Signature

Print Name

Company Name

Date